



## Certificate

### Hygiene – Type Examination

Test institute:	Hygiene Institut des Ruhrgebiets Institut für Umwelthygiene und Toxikologie Rotthauer Straße 21 49879 Gelsenkirchen
Test object:	Humidification unit, frame size „LBE 250“ / „LBE 500“
Manufacturer:	J. Pichler Lufttechnik Gesellschaft m. b. H. Karlweg 5 A-9021 Klagenfurt
Basis of the examination:	✓ VDI 6022,1 (07/2011) ✓ SWKI VA104-01 (04/2006) ✓ VDI 3803, 1 (02/2010) ✓ ÖNORM H 6021 (09/2003)
Validity period:	5 years 02/2012 – 02/2017
Test report:	W-206903kk-12-Ho



In conclusion it can be stated that the examined humidification unit frame size „LBE 250“ / „LBE 500“, as specified in the test report W-206903kk-11-Ho, is in compliance with the above mentioned regulations. Our test results show that as long as the humidification unit „LBE 250 / LBE 500“ is operated as intended, no hygienic problems are to be expected.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)  
Head of the Department of Water Hygiene  
and Environmental Microbiology

(Dipl.-Ing. (FH) S. Horn)  
Department of Water Hygiene  
and Environmental Microbiology

issued 08.02.2012, Gelsenkirchen

Within the framework of the hygiene-type examination the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the type test does not include a toxicological or sensory testing of the introduced materials.

Träger des Instituts: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Gelsenkirchen, Vereinsregister: VR 519 Amtsgericht Gelsenkirchen

USt.-ID: DE125018356, Vorstand: Prof. Dr. Werner Schlake (Vorsitzender), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Volker Vohmann, Prof. Dr. Lothar Dunemann